



PART#: MLD-FG-1836
 DESCRIPTION: 18"X36" SUCTION OUTLET COVER


FLOOR GPM	2,080	WALL GPM	1,496	OPEN AREA	343.44 SQUARE INCH
--------------	-------	-------------	-------	--------------	-----------------------

The above noted product has been certified to comply with section #1404 of the Virginia Graeme Baker (VGBA) Pool & Spa Safety Act. Test results can be obtained by visiting: www.neptunebenson.com and / or <http://www.neptunebenson.com/certification.htm>

DATE OF MANUFACTURE:
 The born-on date will be shown on each product as follows:
 The first dial shows the year of manufacture (ex: 2009) and the second dial shows the month of manufacture (ex: December).

YEAR  MONTH 

Tested to ANSI/ASME 112.19.82007(addendum 8a2008) per Section 1404 of the Virginia Graeme Baker Act (VGB) Pool & Spa Safety Act- December 2008
 Certified by NSF International, 789 N. Dixboro, Road, Ann Arbor, MI. 48113-0140 USA (USA): 800-NSF-MARK (+1) 734-769-8010.



Date of Installation (mm/dd/yy)